


# **Electrical Specifications**

ICN-2S86@120V			
Brand Name	CENTIUM		
Ballast Type	Electronic		
Starting Method	Programmed Start		
Lamp Connection	Series		
Input Voltage	120		
Input Frequency	50/60HZ		
Status	Active		

Lamp Type	Num. of Lamps	Rated Lamp Watts	Min. Start Temp (°F/C)	Input Current (Amps)	Input Power (ANSI Watts)	Ballast Factor	MAX THD %	Power Factor	MAX Lamp Current Crest Factor	B.E.F
* F48T8/HO	1	44	-20/-29	0.50	59	1.02	20	0.98	1.5	1.73
F48T8/HO	2	44	-20/-29	0.84	98	0.95	10	0.98	1.5	0.97
F60T8/HO	1	55	-20/-29	0.58	70	1.00	20	0.98	1.5	1.43
F60T8/HO	2	55	-20/-29	1.04	118	0.92	10	0.98	1.4	0.78
F72T8/HO	1	65	-20/-29	0.68	81	1.00	15	0.98	1.5	1.23
F72T8/HO	2	65	-20/-29	1.21	140	0.94	10	0.98	1.4	0.67
F96T8/HO	1	86	-20/-29	0.84	100	1.00	10	0.98	1.5	1.00
F96T8/HO	2	86	-20/-29	1.57	185	0.95	10	0.98	1.4	0.51




The wiring diagram that appears above is for the lamp type denoted by the asterisk (\*)

Standard Lead Length (inches)

	in.	cm.
Black	22	55.9
White	22	55.9
Blue	46	116.8
Red	46	116.8
Yellow	70	177.8
Gray		0
Violet		0

in	
in.	cm.
	0
	0
	0
	0
	0
	0
	0



## **Enclosure Dimensions**

L	OverAll (L)	Width (W)	Height (H)	Mounting (M)
L	11.75 "	2.875 "	1.78125 "	11.14062 "
	11 3/4	2 7/8	1 25/32	11 9/64
	29.8 cm	7.3 cm	4.5 cm	28.3 cm

### Revised 09/21/2005





Data is based upon tests performed by Philips Lighting Electronics N.A. in a controlled environment and is representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

## PHILIPS LIGHTING ELECTRONICS N.A.



# **Electrical Specifications**

ICN-2S86@120V				
Brand Name	CENTIUM			
Ballast Type	Electronic			
Starting Method	Programmed Start			
Lamp Connection	Series			
Input Voltage	120			
Input Frequency	50/60HZ			
Status	Active			

#### Notes:

Section I - Physical Characteristics

- 1.1 Ballast shall be physically interchangeable with standard electromagnetic or standard electronic ballasts, where applicable,
- 1.2 Ballast shall be provided with integral leads color-coded per ANSI C82.11.

#### Section II - Performance Requirements

- 2.1 Ballast shall be \_\_\_\_\_ (Instant, Rapid or Programmed) Start.
- 2.2 Ballast shall provide Independent Lamp Operation (ILO) for Instant Start ballasts allowing remaining lamp(s) to maintain full light output when one or more lamps fail.
- 2.3 Ballast shall contain auto restart circuitry in order to restart lamps without resetting power (except T8/HO and FT5 ballasts).
- 2.4 Ballast shall operate from 60 Hz input source of 120V, 277V or 347V as applicable with sustained variations of +/- 10% (voltage and frequency). IntelliVolt models shall operate from 50/60 Hz input source of 120V through 277V with sustained variations of +/- 10% (voltage and frequency).
- 2.5 Ballast shall be high frequency electronic type and operate lamps at a frequency above 42 kHz ("GCN" models between 20 kHz and 30kHz) to avoid interference with infrared devices and eliminate visible flicker.
- 2.6 Ballast shall have a Power Factor greater than 0.98 for primary lamp.
- 2.7 Ballast shall have a minimum ballast factor for primary lamp application as follows: 0.75 for Low Watt, 0.85 for Normal Light Output and 1.20 for High Light.
- 2.8 Ballast shall provide for a Lamp Current Crest Factor of 1.7 or less.
- 2.9 Ballast input current shall have Total Harmonic Distortion (THD) of less than 20% for Standard models and THD of less than 10% for Centium models when operated at nominal line voltage with primary lamp.
- 2.10 Ballast shall have a Class A sound rating for all 4-foot lamps and smaller.
- 2.11 Ballast shall have a minimum starting temperature of \_\_\_\_\_ [-18C (0F) for standard T8 and Long Twin Tube lamps, 10C (50F) for standard T12 lamps, 0C (32F) for Slimline T8 lamps and "GCN" models, -29C (-20F) for T8/HO lamps,] for primary lamp application. Ballast shall have a minimum starting temperature of 60F (16C) for energy-saving lamps.
- 2.12 Ballast shall tolerate sustained open circuit and short circuit output conditions.

### Section III - Regulatory Requirements

- 3.1 Ballast shall not contain any Polychlorinated Biphenyl (PCB).
- 3.2 Ballast shall be Underwriters Laboratories (UL) listed, Class P and Type 1 Outdoor; and Canadian Standards Association (CSA) certified where applicable.
- 3.3 Ballast shall comply with ANSI C62.41 Category A for Transient protection.
- 3.4 Ballast shall comply with ANSI C82.11 where applicable.
- 3.5 Ballast shall comply with the requirements of the Federal Communications Commission (FCC) rules and regulations, Title 47 CFR part 18, Non-Consumer (Class A) for EMI/RFI (conducted and radiated).
- 3.6 Ballast shall comply with NEMA 410 for in-rush current limits.

#### Section IV - Other

- 4.1 Ballast shall be manufactured in a factory certified to ISO 9001 Quality System Standards.
- 4.2 Ballast shall carry a five-year warranty from date of manufacture against defects in material or workmanship, including replacement, for operation at a maximum case temperature of 70C.
- 4.3 Manufacturer shall have a twenty-year history of producing electronic ballasts for the North American market.

Note: Energy saving T8 lamps (25W, 28W or 30W) may experience lamp striations if operated on ballasts not rated for their use.

#### Revised 09/21/2005





Data is based upon tests performed by Philips Lighting Electronics N.A. in a controlled environment and is representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

## PHILIPS LIGHTING ELECTRONICS N.A.