



Electrical Specifications

IDL-2S26-M5-BS@120						
Brand Name ROVR						
Ballast Type	Electronic Dimming					
Starting Method	Programmed Start					
Lamp Connection	Series					
Input Voltage	120-277					
Input Frequency	50/60 HZ					
Status	Active					

Lamp Type	Num. of	Rated	Min. Start Temp	Input Current	Input Power (Watts)	Ballast Factor (min/max)	MAX THD	Power Factor	Lamp Current Crest Factor	B.E.F.
	Lamps	Lamp Watts	(°F/C)	(Amps)	(min/max)	(IIIII/IIIax)	%	Factor	Crest Factor	
CFQ13W/G24Q	1	13	50/10	0.15	06/18	0.30/1.00	10	0.99	1.6	5.56
CFQ13W/G24Q	2	13	50/10	0.28	19/33	0.03/1.00	10	0.99	1.6	3.03
CFQ18W/G24Q	1	18	50/10	0.19	07/23	0.03/1.00	10	0.99	1.6	4.35
CFQ18W/G24Q	2	18	50/10	0.34	11/41	0.03/1.00	10	0.99	1.6	2.44
CFQ26W/G24Q	1	26	50/10	0.25	08/30	0.03/1.00	10	0.99	1.6	3.33
* CFQ26W/G24Q	2	26	50/10	0.46	13/55	0.03/1.00	10	0.99	1.6	1.82
CFTR13W/GX24Q	1	13	50/10	0.15	06/18	0.03/1.00	10	0.99	1.6	5.56
CFTR13W/GX24Q	2	13	50/10	0.28	19/33	0.03/1.00	10	0.99	1.6	3.03
CFTR18W/GX24Q	1	18	50/10	0.19	07/23	0.03/1.00	10	0.99	1.6	4.35
CFTR18W/GX24Q	2	18	50/10	0.34	11/41	0.03/1.00	10	0.99	1.6	2.44
CFTR26W/GX24Q	1	26	50/10	0.25	08/30	0.03/1.00	10	0.99	1.6	3.33
CFTR26W/GX24Q	2	26	50/10	0.46	13/55	0.03/1.00	10	0.99	1.6	1.82
CFTR32W/GX24Q	1	32	50/10	0.30	09/36	0.03/1.00	10	0.99	1.6	2.78
CFTR42W/GX24Q	1	42	50/10	0.39	07/47	0.03/1.00	10	0.99	1.6	2.13






Green Terminal Must Be Grounded

Diag. 165

The wiring diagram that appears above is for the lamp type denoted by the asterisk (*)

Standard Lead Length (inches)

	in	om			in.	cm.
	in.	cm.		Yellow/Blue		0
Black	0	0	F	Blue/White		0
White	0	0	-			0
Blue	0	0		Brown		0
Red	0	0		Orange		0
Yellow	0	0		Orange/Black		0
	0	0		Black/White		0
Gray		0		Red/White		0
Violet		0	L	Ited/writte		0



Enclosure Dimensions

1	OverAll (L)	Width (W)	Height (H)	Mounting (M)
	4.98 "	3.00 "	1.18 "	2.00 "
	4 49/50	3	1 9/50	2
	12.6 cm	7.6 cm	3 cm	5.1 cm



Revised 10/23/07

Data is based upon tests performed by Philips Lighting N.A in a controlled environment and representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

Philips Lighting Electronic N.A 10275 West Higgins Road Rosemont, IL 60018 Tel.: 800-322-2086 Fax: 888-432-1882 Customer Support/Technical Service: 800-372-3331 · OEM Support: 866-915-5886

PHILIPS ADVANCE

Electrical Specifications

Notes:

Section I - Physical Characteristics

1.1 Ballast shall be physically interchangeable with standard electromagnetic or standard electronic ballasts, where applicable.

1.2 Ballast shall be available in a plastic/metal can or all metal can construction to meet all plenum requirements.

1.3 Ballast shall be provided with poke-in wire trap connectors or integral leads color coded per ANSI C82.11.

Section II - Performance Requirements

2.1 Ballast shall be Programmed Start.

2.2 Ballast shall be provided with integral protection circuitry to withstand connection of low voltage control leads to mains power supply. In this event, ballast shall default to maximum light output.

2.3 Ballast shall contain auto restart circuitry in order to restart lamps without resetting power.

2.4 Ballast shall operate from 50/60 Hz input source of 120V or 277V with sustained variations of +/- 10% (voltage and frequency). IntelliVolt models shall operate from 50/60 Hz input source of 120V through 277V with sustained variations of +/- 10% (voltage and frequency).

2.5 Ballast shall be high frequency electronic type and operate lamps at a frequency above 42 kHz to avoid interference with infrared devices and eliminate visible flicker.

2.6 Ballast shall have a Power Factor greater than 0.98 at full light output and greater than 0.90 throughout the dimming range for primary lamp.

2.7 Ballast shall have a minimum ballast factor of 1.00 at maximum light output and 0.03 at minimum light output for primary lamp application. 2.8 Ballast shall provide for a Lamp Current Crest Factor of 1.7 or less.

2.9 Ballast input current shall have Total Harmonic Distortion (THD) of less than 10% when operated at nominal line voltage with primary lamp. 2.10 Ballast shall have a Class A sound rating.

2.11 Ballast shall have a minimum starting temperature of 10C (50F) for primary lamp.

2.12 Ballast shall provide Lamp EOL Protection Circuit for all T5, T5/HO and CFL lamps.

2.13 Ballast shall control lamp light output from 100% - 3% relative light output for T8 and CFL lamps and 100% - 1% relative light output for T5/HO lamps.

2.14 Ballast shall ignite the lamps at any light output setting without first going to another output setting.

2.15 Ballast shall tolerate sustained open circuit and short circuit output conditions.

Section III - Regulatory Requirements

3.1 Ballast shall not contain any Polychlorinated Biphenyl (PCB).

3.2 Ballast shall be Underwriters Laboratories (UL) listed, Class P and Type 1 Outdoor; and Canadian Standards Association (CSA) certified where applicable.

3.3 Ballast shall comply with ANSI C62.41 Category A for Transient protection.

3.4 Ballast shall comply with ANSI C82.11 where applicable.

3.5 Ballast shall comply with the requirements of the Federal Communications Commission (FCC) rules and regulations, Title 47 CFR part 18, Non-Consumer (Class A) for EMI/RFI (conducted and radiated).

3.6 Ballast shall comply with NEMA 410 for in-rush current limits.

Section IV - Other

4.1 Ballast shall be manufactured in a factory certified to ISO 9001 Quality System Standards.

4.2 Ballast shall carry a five-year warranty from date of manufacture against defects in material or workmanship, including replacement, for operation at a maximum case temperature of 70C.

4.3 Manufacturer shall have a twenty-year history of producing electronic ballasts for the North American market.

4.4 Ballast shall be controlled by a compatible DALI protocol control.

4.5 Ballast shall be Philips Advance part # _____ or approved equal.



Revised 10/23/07

Data is based upon tests performed by Philips Lighting Electronic N.A. in a controlled environment and representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

Philips Lighting Electronic N.A.

10275 West Higgins Road Rosemont, IL 60018 Tel.: 800-322-2086 Fax: 888-432-1882 Customer Support/Technical Service: 800-372-3331 · OEM Support: 866-915-5886

IDL-2S26-M5-BS@120Brand NameROVRBallast TypeElectronic DimmingStarting MethodProgrammed StartLamp ConnectionSeriesInput Voltage120-277

50/60 HZ

Active

Input Frequency

Status




Electrical Specifications

IDL-2S26-M5-BS@277							
Brand Name	ROVR						
Ballast Type	Electronic Dimming						
Starting Method	Programmed Start						
Lamp Connection	Series						
Input Voltage	120-277						
Input Frequency	50/60 HZ						
Status	Active						

Lamp Type	Num.	Rated	Min. Start	Input	Input Power (Watts)	Ballast Factor	MAX THD	Power	Lamp Current Crest Factor	B.E.F.
	of Lamps	Lamp Watts	Temp (℉/C)	Current (Amps)	(watts) (min/max)	(min/max)	1HD %	Factor	Crest Factor	
CFQ13W/G24Q	1	13	50/10	0.07	06/18	0.03/1.00	10	0.99	1.6	5.56
CFQ13W/G24Q	2	13	50/10	0.12	19/33	0.03/1.00	10	0.99	1.6	3.03
CFQ18W/G24Q	1	18	50/10	0.09	07/23	0.03/1.00	10	0.99	1.6	4.35
CFQ18W/G24Q	2	18	50/10	0.15	11/41	0.03/1.00	10	0.99	1.6	2.44
* CFQ26W/G24Q	1	26	50/10	0.11	08/30	0.03/1.00	10	0.99	1.6	3.33
CFQ26W/G24Q	2	26	50/10	0.20	13/55	0.03/1.00	10	0.99	1.6	1.82
CFTR13W/GX24Q	1	13	50/10	0.07	06/18	0.03/1.00	10	0.99	1.6	5.56
CFTR13W/GX24Q	2	13	50/10	0.12	19/33	0.03/1.00	10	0.99	1.6	3.03
CFTR18W/GX24Q	1	18	50/10	0.09	07/23	0.03/1.00	10	0.99	1.6	4.35
CFTR18W/GX24Q	2	18	50/10	0.15	11/41	0.03/1.00	10	0.99	1.6	2.44
CFTR26W/GX24Q	1	26	50/10	0.11	08/30	0.03/1.00	10	0.99	1.6	3.33
CFTR26W/GX24Q	2	26	50/10	0.20	13/55	0.03/1.00	10	0.99	1.6	1.82
CFTR32W/GX24Q	1	32	50/10	0.13	09/36	0.03/1.00	10	0.99	1.6	2.78
CFTR42W/GX24Q	1	42	50/10	0.17	09/47	0.03/1.00	10	0.99	1.6	2.13

Wiring Diagram WIRING: (2) QUAD/TRIPLE LAMPS (1) QUAD/TRIPLE LAMP GREE RUIF




Green Terminal Must Be Grounded

Diag. 165

The wiring diagram that appears above is for the lamp type denoted by the asterisk (*)

Standard Lead Length (inches)

	in.	cm.]		in.	cm.
Black	0	0		Yellow/Blue		0
White	0	0		Blue/White		0
Blue	0	0		Brown		0
Red	0	-		Orange		0
	0	0	-	Orange/Black		0
Yellow	0	0		Black/White		0
Gray		0	-	Red/White		0
Violet		0				0



Enclosure Dimensions

1	OverAll (L)	Width (W)	Height (H)	Mounting (M)
	4.98 "	3.00 "	1.18 "	2.00 "
	4 49/50	3	1 9/50	2
	12.6 cm	7.6 cm	3 cm	5.1 cm



Revised 10/23/07

Data is based upon tests performed by Philips Lighting N.A in a controlled environment and representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

Philips Lighting Electronic N.A 10275 West Higgins Road Rosemont, IL 60018 Tel.: 800-322-2086 Fax: 888-432-1882 Customer Support/Technical Service: 800-372-3331 · OEM Support: 866-915-5886

PHILIPS ADVANCE

Electrical Specifications

Notes:

Section I - Physical Characteristics

1.1 Ballast shall be physically interchangeable with standard electromagnetic or standard electronic ballasts, where applicable.

1.2 Ballast shall be available in a plastic/metal can or all metal can construction to meet all plenum requirements.

1.3 Ballast shall be provided with poke-in wire trap connectors or integral leads color coded per ANSI C82.11.

Section II - Performance Requirements

2.1 Ballast shall be Programmed Start.

2.2 Ballast shall be provided with integral protection circuitry to withstand connection of low voltage control leads to mains power supply. In this event, ballast shall default to maximum light output.

2.3 Ballast shall contain auto restart circuitry in order to restart lamps without resetting power.

2.4 Ballast shall operate from 50/60 Hz input source of 120V or 277V with sustained variations of +/- 10% (voltage and frequency). IntelliVolt models shall operate from 50/60 Hz input source of 120V through 277V with sustained variations of +/- 10% (voltage and frequency).

2.5 Ballast shall be high frequency electronic type and operate lamps at a frequency above 42 kHz to avoid interference with infrared devices and eliminate visible flicker.

2.6 Ballast shall have a Power Factor greater than 0.98 at full light output and greater than 0.90 throughout the dimming range for primary lamp.

2.7 Ballast shall have a minimum ballast factor of 1.00 at maximum light output and 0.03 at minimum light output for primary lamp application. 2.8 Ballast shall provide for a Lamp Current Crest Factor of 1.7 or less.

2.9 Ballast input current shall have Total Harmonic Distortion (THD) of less than 10% when operated at nominal line voltage with primary lamp. 2.10 Ballast shall have a Class A sound rating.

2.11 Ballast shall have a minimum starting temperature of 10C (50F) for primary lamp.

2.12 Ballast shall provide Lamp EOL Protection Circuit for all T5, T5/HO and CFL lamps.

2.13 Ballast shall control lamp light output from 100% - 3% relative light output for T8 and CFL lamps and 100% - 1% relative light output for T5/HO lamps.

2.14 Ballast shall ignite the lamps at any light output setting without first going to another output setting.

2.15 Ballast shall tolerate sustained open circuit and short circuit output conditions.

Section III - Regulatory Requirements

3.1 Ballast shall not contain any Polychlorinated Biphenyl (PCB).

3.2 Ballast shall be Underwriters Laboratories (UL) listed, Class P and Type 1 Outdoor; and Canadian Standards Association (CSA) certified where applicable.

3.3 Ballast shall comply with ANSI C62.41 Category A for Transient protection.

3.4 Ballast shall comply with ANSI C82.11 where applicable.

3.5 Ballast shall comply with the requirements of the Federal Communications Commission (FCC) rules and regulations, Title 47 CFR part 18, Non-Consumer (Class A) for EMI/RFI (conducted and radiated).

3.6 Ballast shall comply with NEMA 410 for in-rush current limits.

Section IV - Other

4.1 Ballast shall be manufactured in a factory certified to ISO 9001 Quality System Standards.

4.2 Ballast shall carry a five-year warranty from date of manufacture against defects in material or workmanship, including replacement, for operation at a maximum case temperature of 70C.

4.3 Manufacturer shall have a twenty-year history of producing electronic ballasts for the North American market.

4.4 Ballast shall be controlled by a compatible DALI protocol control.

4.5 Ballast shall be Philips Advance part # _____ or approved equal.



Revised 10/23/07

Data is based upon tests performed by Philips Lighting Electronic N.A. in a controlled environment and representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.

Philips Lighting Electronic N.A.

10275 West Higgins Road Rosemont, IL 60018 Tel.: 800-322-2086 Fax: 888-432-1882 Customer Support/Technical Service: 800-372-3331 · OEM Support: 866-915-5886

IDL-2S26-M5-BS@277Brand NameROVRBallast TypeElectronic DimmingStarting MethodProgrammed StartLamp ConnectionSeriesInput Voltage120-277

50/60 HZ

Active

Input Frequency

Status