Nominal Length (in)

Nominal Wattage (W)

Return to search	Print Page
	Product 21781 Number: Order F032/841/EC0
Providence - 700	Abbreviation: General Description: 32W, 48" MOL, T8 OCTRON fluorescent lamp, 4100K color temperature, rare earth phosphor, 85 CRI, suitable for IS or RS operation, ECOLOGIC
Pre	oduct Information
Abbrev. With Packaging Info.	FO32841ECO 30/CS 1/SKU
Actual Length (in)	47.78
Actual Length (mm)	1213.6
Average Rated Life (hr)	30000
Base	Medium Bipin
Bulb	T8
Color Rendering Index (CRI)	85
Color Temperature/CCT (K)	4100
Diameter (in)	1.10
Diameter (mm)	27.9
Family Brand Name	Octron® 800, Ecologic
Industry Standards	ANSI C78.81 - 2001
Initial Lumens at 25C	2950
Mean Lumens at 25C	2802

Additional Product Information	
Product Documents, Graphs, and Images	
Compatible Ballast	
Packaging Information	

48

32.00



http://ecom.mysylvania.com/sylvaniab2c/catalog/updateItems.do

6/17/2008

## Footnotes

- The life rating of FO32/800/ECO OCTRON® lamps operated on rapid start ballasts is 30,000 hours. The life rating of FO32/800/ECO OCTRON lamps operated on instant start ballasts is 24,000 hours.
- Approximate initial lumens after 100 hours operation.
- The life ratings of fluorescent lamps are based on 3 hr. burning cycles under specified conditions and with ballast meeting ANSI specifications. If burning cycle is increased, there will be a corresponding increase in the average hours life.
- Minimum starting temperature is a function of the ballast; consult the ballast manufacturer.
- OCTRON lamps should be operated only with magnetic rapid start ballasts designed to
  operate 265 mA, T-8 lamps or high frequency (electronic) ballasts that are either instant
  start, or rapid start, or programmed rapid start specifically designed to operate T8 lamps.
  OCTRON lamps may be operated on instant start ballasts with ballast factors ranging
  from a minimum of 0.71 to a maximum of 1.20 at the nominal ballast input voltage.
  When OCTRON lamps are operated in the instant start mode, the two wires or two
  contacts of each socket should be connected to each other. They should then be
  connected to the appropriate ballast lead wire using National Electric Code techniques.
- SYLVANIA ECOLOGIC fluorescent lamps are designed to pass the Federal Toxic Characteristic Leaching Procedure (TCLP) criteria for classification as non-hazardous waste in most states. TCLP test results are available upon request. Lamp disposal regulations may vary, check your local & state regulations. For more information, please visit www.lamprecycle.org

Print Page