

M2012CK-6EU-J

APPLICATION and PERFORMANCE SPECIFICATION

Description: Mini-Square - electronic low frequency square wave ballast for 20W metal halide lamps

- Line Voltage: 120vac , ±10%, 50/60Hz
- Microprocessor controlled
- RoHS Compliant
- Mounting type: Studs - top lead exit
- Resonance Start
- Active power factor correction
- Abnormal operation shutdown circuit: Line voltage must be reset

*60 Hz data

Lamp		Volts	Input Watts	Nominal Line Amps	Power Factor	Ballast Factor	Harmonic Total	Crest Factor
ANSI Type	#							
M156/C156	1	120	23	0.20	> 95%	1.00	< 6%	<1.5

Ballast Order Code: 188627

Performance:

- Meets ANSI Standard C82.14-2006
- Meets ANSI Standard C62.41-1991
- Meets FCC Part 18C for EMI & RFI (non-consumer)
- EOL Protection

Safety:

- No PCBs
- cUL_{US} Listed (Outdoor Type 1)
- Thermal Protection

Application:

- Minimum Starting Temperature: -15°C/+5°F
- Maximum Case Temperature: 75°C/ 167°F
- Sound Rated: A
- Remote Mounting: 10 feet

Physical Parameters

Inches/Metric

- Overall Length: 3.52"/89.4mm
- Width: 3.00"/76.2mm
- Height: 1.56"/39.7mm
- Weight: 9 oz
- Lead lengths: 7"/177.8mm
- Lead stripping:(Tinned) All .375"/9.53mm

Each lamp's lead wires must be run in a separate minimum 1/2" ID conduit from the input leads to achieve good EMI performance and maximum remote capabilities. Individual, unbundled lead wires must be used for extension wiring using wire types SF-2 or SFF-2 or equivalent. Power cords and MC cables are not acceptable extension wiring methods.

Warranty:

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 3 years from date of manufacture when properly installed and under normal conditions of use. The normal operation of 4000 hr./yr. is used for the warranty period. Longer operating times will adjust the warranty period accordingly. For extended warranty periods greater than 36 months, call **1-800 BALLAST** for fixture testing instructions.

Manufactured in Japan

