

# M2212CK-7EUN-J

## APPLICATION and PERFORMANCE SPECIFICATION

**Description:** Micro - electronic low frequency square wave ballast for 22W metal halide lamps

- Line Voltage: 120vac , ±10%, 50/60Hz
- Microprocessor controlled
- RoHS Compliant
- Mounting type: Studs - top lead exit
- Resonance Start
- Active power factor correction
- Abnormal operation shutdown circuit: Line voltage must be reset

\*60 Hz data

Lamp		Volts	Input Watts	Nominal Line Amps	Power Factor	Ballast Factor	Harmonic Total	Crest Factor
ANSI Type	#							
<b>M175/C175</b>	<b>1</b>	<b>120</b>	<b>26.5</b>	<b>0.22</b>	<b>&gt; 95%</b>	<b>1.00</b>	<b>&lt; 5%</b>	<b>&lt;1.5</b>

**Ballast Order Code:** 188885

**Performance:**

- Meets ANSI Standard C82.14-2006
- Meets ANSI Standard C62.41-1991
- Meets FCC Part 18C for EMI & RFI (non-consumer)
- EOL Protection

**Safety:**

- No PCBs
- cUL<sub>US</sub> Listed (Outdoor Type 1)
- Thermal Protection

**Application:**

- Minimum Starting Temperature: -15°C/+5°F
- Maximum Case Temperature: 85°C/ 185°F
- Sound Rated: A
- Remote Mounting: 5 feet

**Physical Parameters**

**Inches/Metric**

- Overall Length: 3.81"/96.7mm
- Width: 1.32"/33.5mm
- Height: 1.50"/38.1mm
- Weight: 7 oz
- Lead lengths: 7"/177.8mm
- Lead stripping:(Tinned) All .375"/9.53mm

Each lamp's lead wires must be run in a separate minimum 1/2" ID conduit from the input leads to achieve good EMI performance and maximum remote capabilities. Individual, unbundled lead wires must be used for extension wiring using wire types SF-2 or SFF-2 or equivalent. Power cords and MC cables are not acceptable extension wiring methods.

**Warranty:**

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 3 years from date of manufacture when properly installed and under normal conditions of use. The normal operation of 4000 hr./yr. is used for the warranty period. Longer operating times will adjust the warranty period accordingly. For extended warranty periods greater than 36 months, call **1-800 BALLAST** for fixture testing instructions.

**Manufactured in North America**

