

M3912/27CK-5EU-JT3

APPLICATION and PERFORMANCE SPECIFICATION

Standard - electronic low frequency square wave ballast for 39W metal halide lamps with 120V "tap" for 3 or Description:

4-wire self heating thermal protectors (IDTPs)

• Line Voltage: 120/277vac, +/-10%, 50/60Hz

RoHS Compliant

Microprocessor controlled

• Mounting type: Studs - Top lead exit

*60 Hz data

_	Resonance	Ctort
•	Resonance	Start

· Active power factor correction

CUL_{US} Listed (Outdoor Type 1)

Inches/Metric

5.02"/127.5mm

3.62"/92.0mm

1.57"/39.9mm

20 07

7"/178mm

.375"/9.53mm

· Abnormal operation shutdown circuit: Line

voltage must be reset

Safety:

No PCBs

Thermal Protection

Physical Parameters

· Overall Length:

· Width:

· Height:

• Weight:

Lamp		Volts	Input	Nominal	Power	Ballast	Harmonic	Crest
ANSI Type	#	VOILS	Watts	Line Amps	Factor	Factor	Total	Factor
M130/C130	1	120	44 w/o IDTP	0.37	> 95%	1.00	< 5%	<1.5
		277	44 w/o IDTP	0.17	> 95%	1.00	< 11%	<1.5
	1	120	46 w/IDTP	0.39	> 95%	1.00	< 4%	<1.5
		277	46 w/IDTP	0.18	> 95%	1.00	< 9%	<1.5

Ballast Order Code: 188629

Performance:

- Meets ANSI Standard C82.14-2006
- Meets ANSI Standard C62.41-1991
- Meets FCC Part 18C for EMI & RFI (non-consumer)
- EOL Protection

Application:

- IDTP "tap" Function: Provides 120V to heaters of IDTPs.
- Compatible with 3 or 4 wire IDTPs
- Operation with IDTP is dual voltage rated for 120V or 277V.
- Can be operated as normal HID ballast with tap lead capped-off for entire 120V to 277V input voltage range

• Minimum Starting Temperature: -15°C/+5°F · Maximum Case Temperature: Sound Rated:

· Remote Mounting:

15 Feet Note: Each lamp's lead wires must be run in a separate minimum 1/2" ID conduit from the input leads to achive good EMI performance and maximum remote capabilities. Individual, unbundled lead wires must be used for extension wiring using wire types SF-2 or SFF-2 or equivalent. Power cords and MC cables are not acceptable extension wiring methods.

· Lead lengths: All

Lead stripping:(Tinned) All

80°C/176°F

Warranty:

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 3 years from date of manufacture when properly installed and under normal conditions of use. The normal operation of 4000 hr./yr. is used for the warranty period. Longer operating times will adjust the warranty period accordingly. For extended warranty periods greater than 36 months, call 1-800 BALLAST for fixture testing instructions.

Manufactured in North America





