

M3912-27CK-5EU

APPLICATION and PERFORMANCE SPECIFICATION

Description: Standeard Case - electronic low frequency square wave ballast for 39W metal halide lamps

• Line Voltage: 120 - 277vac, ±10%, 50/60Hz

Microprocessor controlled

RoHS Compliant

• Mounting Type: No feet - side lead exit

*60 Hz data

· Resonance Start

· Active power factor correction

· Abnormal operation shutdown circuit: Line

voltage must be reset

Lamp		Volts	Input	Nominal	Power	Ballast	Harmonic	Crest
ANSI Type	#	VOILS	Watts	Line Amps	Factor	Factor	Total	Factor
M130/C130	1	120	44	0.37	> 95%	1.00	< 7%	<1.5
		277	44	0.17	> 95%	1.00	< 11%	<1.5

188156 **Ballast Order Code:**

Performance:

- Meets ANSI Standard C82.14-2006
- Meets ANSI Standard C62.41-1991
- Meets FCC Part 18C for EMI & RFI (non-consumer)
- EOL Protection

Safety:

- No PCBs
- _CUR_{US} recognized component
- Thermal Protection

Application:

· Minimum Starting Temperature: -15°C/+5°F • Maximum Case Temperature: 80°C/176°F · Sound Rated: Α · Remote Mounting: 15 feet

Each lamp's lead wires must be run in a separate minimum 1/2" ID conduit from the input • Weight: leads to achive good EMI performance and maximum remote capabilities. Individual, unbundled lead wires must be used for extension wiring using wire types SF-2 or SFF-2 $\,$ or equivalent. Power cords and MC cables are not acceptable extension wiring methods. • Lead stripping:(Tinned) All

Physical Parameters

Inches/Metric • Overall Length: 5.26"/133.5mm • Width: 3.62"/92.6mm · Height: 1.57"/39.9mm 20 oz

· Lead lengths: All 10"/254mm .375"/9.53mm

Warranty:

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 3 years from date of manufacture when properly installed and under normal conditions of use. The normal operation of 4000 hr./yr. is used for the warranty period. Longer operating times will adjust the warranty period accordingly. For extended warranty periods greater than 36 months, call 1-800 BALLAST for fixture testing instructions.

Manufactured in North America



